



IECEx certificate:

EN

IECEx LCI 06.0007X

for CP 23x



Meggitt SA
Route de Moncor 4
PO Box 1616
CH - 1701 Fribourg
Switzerland

THIS PAGE INTENTIONALLY LEFT BLANK

IECEx Certificate
 of Conformity



Certificate No.: IECEx LCI 06.0007X Issue No.: 3
 Date of Issue: 2011-12-23 Page 2 of 4

Manufacturer: **Meggitt SA**
 Route de Moncor 4
 1752 Villars-sur-Glâne
 Switzerland

Manufacturing location(s):
Meggitt SA
 Route de Moncor 4
 1752 Villars-sur-Glâne
 Switzerland

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:
 The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

- IEC 60079-0 : 2007-10** Explosive atmospheres - Part 0: Equipment - General requirements Edition: 5
- IEC 60079-11 : 2006** Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "I" Edition: 5

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report: FR/LCI/EXTR06.0011/00 FR/LCI/EXTR06.0011/03	FR/LCI/EXTR06.0011/01 FR/LCI/EXTR06.0011/02
Quality Assessment Report: FR/LCI/QA06.0006/00 FR/LCI/QA06.0006/03	FR/LCI/QA06.0006/01 FR/LCI/QA06.0006/02

IECEx Certificate
 of Conformity



INTERNATIONAL ELECTROTECHNICAL COMMISSION
 IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx LCI 06.0007X Issue No.: 3

Status: **Current**

Date of Issue: 2011-12-23 Page 1 of 4

Applicant: **Meggitt SA**
 Route de Moncor 4
 1752 Villars-sur-Glâne
 Switzerland

Electrical Apparatus: **Dynamic pressure sensor type PNR 143-23X-000-YYY**

Optional accessory:

Type of Protection: **ib**

Marking: **Vibro-meter or MEGGITT or MFR S3960**

Address: ...
 Type : PNR 143-23X-000-YYY
 DNF: rnyyyyy
 Serial number : ...
 Year of construction : ...
 Ex Ib IIC 16 to T500°C Gb
 IECEx LCI 06.0007X
 UI = ..., PI = ..., I = ..., CI = ..., LI = ... (1)
 (1) completed with the electrical parameters

Approved for issue on behalf of the IECEx

Certification Body: **Julien GAUTHIER**

Position: **Certification Officer**

Signature: *(for printed version)*

Date: **December 28, 2011**

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.



Certificate issued by:



Laboratoire Central des Industries Electriques (LCIE)
 33 Avenue du General Leclerc
 FR-92260 Fontenay-aux-Roses
 France



Certificate history:
 Issue No. 3 (2011-12-23)
 Issue No. 2 (2010-10-25)
 Issue No. 1 (2008-10-1)
 Issue No. 0 (2006-7-3)

Michel BRÉNON
(Signature)
 December 28, 2011

 	<h2>IECEx Certificate of Conformity</h2>
Certificate No.: IECEx LCI 06.0007X Date of issue: 2011-12-23	Issue No.: 3 Page 4 of 4
DETAILS OF CERTIFICATE CHANGES (for issues 1 and above): Normative update according to standard IEC 60079-0, Ed 5 Update type	

 	<h2>IECEx Certificate of Conformity</h2>
Certificate No.: IECEx LCI 06.0007X Date of issue: 2011-12-23	Issue No.: 3 Page 3 of 4
Schedule	
EQUIPMENT: <i>Equipment and systems covered by this certificate are as follows:</i>	
DESCRIPTION Dynamic pressure sensor The sensor is an electro mechanic transducer delivering at its terminal blocks an electrical load proportional to the measured pressure. It works with a piezoelectric equipment mounted in compression. The mineral insulating cable and the connector are fully in apart of the sensor.	
SPECIFIC PARAMETERS OF THE MODE OF PROTECTION "ib" $U_i \leq 30 \text{ Vdc}$; $I_i \leq 130 \text{ mA}$; $P_i \leq 0,8 \text{ W}$ $C_i \leq 1,6 \text{ nF}$ (with 5 m of cable) $R_i = 0$ $L_i = 0$	
CONDITIONS OF CERTIFICATION: YES as shown below:	
Special conditions for safe use Electrical parameters of any IS certified equipment connected to the sensor shall not exceed the following values: $U_o \leq 30 \text{ Vdc}$; $I_o \leq 130 \text{ mA}$; $P_o \leq 0,8 \text{ W}$ Operating ambient temperature: -200°C to $+550^\circ\text{C}$. Temperature classification in function of the operating temperature: T6 at Tamb. $+80^\circ\text{C}$; T5 at Tamb. $+95^\circ\text{C}$ T4 at Tamb. $+130^\circ\text{C}$; T3 at Tamb. $+195^\circ\text{C}$ T2 at Tamb. $+290^\circ\text{C}$; T1 at Tamb. $+440^\circ\text{C}$ T360 C at Tamb. $+550^\circ\text{C}$ The equipment shall only be connected to a certified IS apparatus and this combination shall be compatible as regards intrinsic safety. During installation, the fixation of the housing shall be bounded.	